


03.01-03/24/92-00118



State of North Carolina  
Department of Environment, Health, and Natural Resources  
Division of Solid Waste Management  
P.O. Box 27687 · Raleigh, North Carolina 27611-7687

March 24, 1992

James G. Martin, Governor  
William W. Cobey, Jr., Secretary

William L. Meyer  
Director

Commander, Atlantic Division  
Naval Facilities Engineering Command  
Code 1822  
Attention:

MCB Camp Lejeune, RPM  
Mr. Bryon Brant  
Norfolk, Virginia 23511-6287

Commanding General

Attention: AC/S, Environmental Management  
Building 1, Marine Corps Base  
Camp Lejeune, North Carolina 28542-5001

Subject: Remedial Investigation/Feasibility Study-Hadnot Point Industrial Area  
USMC Camp Lejeune Military Reservation  
NC6 170 022 580  
Jacksonville, Onslow County, North Carolina

Dear Sir and Madam:

Attached please find comments from the NC Division of Environmental Management concerning the subject documents. These comments are in addition to those previously submitted by the NC Superfund Section. If you have any questions please contact me at (919) 733-2801.

Sincerely,

A handwritten signature in cursive script that reads "Jack Butler".

Jack Butler, Environmental Engineer  
Superfund Section

Attachment

cc: Michelle M. Glenn, EPA Region IV, w/attachment



RECEIVED  
MAR 25 1992  
SUPERFUND SECTION

State of North Carolina  
Department of Environment, Health, and Natural Resources  
Division of Environmental Management  
512 North Salisbury Street • Raleigh, North Carolina 27604

James G. Martin, Governor  
William W. Cobey, Jr., Secretary

March 5, 1992

George T. Everett, Ph.D.  
Director

MEMORANDUM

TO: Lee Crosby, Chief  
Superfund Section  
Division of Solid Waste Management

FROM: George T. Everett, Director *George T. Everett*  
Division of Environmental Management

SUBJECT: Remedial Investigation - Feasibility Study  
Camp Le Jeune - Hadnot Point  
Onslow County NCD6170022580  
Project #91-68

As requested, the Division of Environmental Management has reviewed the Remedial Investigation - Feasibility Study for the subject report. The comments from our Water Quality, Air Quality and Groundwater Sections are provided below:

Water Quality Section:

1. The "Waiver" alluded to in the report is not an option. Any waste stream not covered in the NPDES Permit would require the amendment to that permit which authorized the acceptance of the wastewater. As the report indicated, one of the primary concerns from a water quality perspective is the possibility of adverse impact on the trickling filter system.
2. A request has been submitted to the technical support branch for "preliminary" effluent limitations that may be applied to any proposed direct discharge from the remediation facilities and for the amendment to the Hadnot Point effluent limitations. In either case, an authorization to construct treatment facilities will be required.

Regional Offices

Asheville 704/251-6208	Fayetteville 919/486-1541	Mooresville 704/663-1699	Raleigh 919/733-2314	Washington 919/946-6481	Wilmington 919/395-3900	Winston-Salem 919/761-2351
---------------------------	------------------------------	-----------------------------	-------------------------	----------------------------	----------------------------	-------------------------------

Air Quality Section:

An Air Quality permit is required if more than 40 pounds per day of volatile organic compounds are emitted. Registration as an air pollution source is required if emissions are less than 40 lbs/day.

Groundwater Section:

1. The minimum treatment required is a combination of alternatives 3 and 4; i.e., oil/water separator, chemical reduction system, air stripper and a carbon adsorption system.
2. The minimum treatment to pretreat the groundwater prior to discharge into the Hadnot Point wastewater treatment facility will require authorization to construct from the Division.

Should you have any questions or concerns, please contact Mr. Preston Howard, Wilmington Regional Office at (919) 395-3900.

NT/pkh:Lejeune.Inv