

North Carolina
Department of Environment and Natural Resources
Wilmington Regional Office
Division of Waste Management
UST Section



Michael F. Easley, Governor
William G. Ross Jr., Secretary
Dexter R. Matthews, Director

August 27, 2004

Ms. Nikki Hall
Attn: Director, I & E/EMD/EQB
Marine Corps Base
PSC Box 20004
Camp Lejeune, NC 28542-0004

Re: Notice of Regulatory Requirements
15A NCAC 2L .0115(i)
Risk-based Assessment and Corrective Action Petroleum Underground Storage Tanks
USMC-Camp Lejeune, Bldg. H-30
Incident No. 23091
Piner Road, Onslow County
Low Risk Classification

Dear Ms. Hall:

The Underground Storage Tank (UST) Section of the Division of Waste Management Regional Office has reviewed the Soil Assessment Report dated June 22, 2004 for the above-referenced site. The UST Section staff agrees with both the plan and the schedule for remediating contaminated soil with the following modifications:

Please be aware that since the extent of soil contamination was not defined in the Soil Assessment Report, and that if the confirmation samples are over residential standards, more soil may have to be excavated from the site. The Base may also want to consider removal of the originally excavated material that was placed back into the tank basin.


Ms. Nikki Hall
August 27, 2004
Page 2

implementation of the plan is disposed of in accordance with all applicable county, state and federal laws.

Also note that performing assessment and cleanup work that is not required under 15A NCAC 2L .0115 is not reimbursable from the Commercial or Noncommercial Leaking Petroleum Underground Storage Tank Cleanup Funds. Your prompt attention to the items described herein is required. Failure to comply with the state's rules in the manner and time specified, may result in the assessment of civil penalties and /or the use of other enforcement mechanisms available to the state. Each day that a violation continues may be considered a separate violation.

If you have any questions regarding the actions that must be taken or the rules mentioned in this letter, please contact me at the letterhead address or at (910) 395-3900. If you have any questions regarding trust fund eligibility or reimbursement, please contact the UST Section Trust Fund Branch in Raleigh at (919) 733-8486.

Sincerely,



Bruce Reed
Hydrogeologist II

BR

cc: George O'Daniel (Onslow County Health Department)
WiRO-UST

bruce/hallh30.scf