



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET, N.E.  
ATLANTA, GEORGIA 30365

APR 14 1992

4WD-RCRA/FF

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Mr. Byron Brant  
Department of the Navy - Atlantic Division  
Naval Facilities Engineering Command  
Code 1822  
Norfolk, Virginia 23511-6287

RE: Marine Corps Base Camp Lejeune NPL Site  
Jacksonville, North Carolina

Dear Mr. Brant:

This letter is in response to Mr. P. A. Rakowski's letter dated April 6, 1992 in reference to the treatment of TCE contaminated groundwater from the Hadnot Point shallow aquifer.

I have consulted with our RCRA experts and offer the following position on this issue. If the wastewater enters a surface impoundment at any time in the treatment process the RCRA regulations would apply a "Applicable or Relevant and Appropriate" (ARARs) that must be met by the treatment process. Section 121(e) of CERCLA states:

Permits and Enforcement. (1) No Federal, State, or local permit shall be required for the portion of any removal or remedial action conducted entirely onsite, where such remedial action is selected and carried out in compliance with this section.

It will be necessary to meet the substantive technical requirements of CFR 264.

If you have any questions or comments, please call me at (404) 347-3016.

Sincerely,

A handwritten signature in cursive script that reads "Michelle M. Glenn".

Michelle M. Glenn  
Senior Project Manager

cc: Jack Butler, NCDEHNR  
George Radford, MCB Camp Lejeune

UNITED STATES  
ENVIRONMENTAL PROTECTION AGENCY  
REGION IV  
345 COURTLAND STREET  
ATLANTA GEORGIA 30365

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300


RECEIVED  
CODE 0112

92 APR 16 AM 8:28

87

OPENED AND INSPECTED  
FOR CLASSIFIED MATERIAL  
BY COB 0112  
DATE 4-16-92

*S. Ruchlow*



*Mr. Byron Brand* 6LNS0001  
COMMANDER, ATLANTIC DIVISION  
NAVAL FACILITIES ENGINEERING COMMAND  
CODE 1822  
NORFOLK VA 23511-6287



Doc No : 0265-00097-13.01-4/14/92