

06, 01-09/21/92-00816



State of North Carolina
Department of Environment, Health, and Natural Resources
Division of Solid Waste Management
P.O. Box 27687 · Raleigh, North Carolina 27611-7687

James G. Martin, Governor
William W. Cobey, Jr., Secretary

William L. Meyer
Director

September 21, 1992

Commander, Atlantic Division
Naval Facilities Engineering Command
Code 1822
Attention: MCB Camp Lejeune, RPM
Ms. Linda Berry
Norfolk, Virginia 23511-6287

Commanding General
Attention: AC/S, Environmental Management
Building 1, Marine Corps Base
Camp Lejeune, North Carolina 28542-5001

RE: MCB Camp Lejeune, Draft Record of Decision for the Interim Remedial Action,
Shallow Aquifer at the Hadnot Point Industrial Area, NC 6170 022 580

Dear Ms. Berry:

The purpose of this letter is to document that the existing N.P.D.E.S. permit and recently issued S.O.C. permit governing the operation of the Hadnot Point Sewage Treatment Plant will not be required to go through formal modification or renewal as a result of the proposed discharge of treated groundwater resulting from the Interim Remedial Action of the Shallow Aquifer at the Hadnot Point Industrial Area, provided the following conditions are satisfied:

1. The proposed extracted groundwater will be treated by oil/water separation, metal precipitation, and air stripping as a minimum. A Bench Study shall be performed to determine the necessity of Activated Carbon Adsorption to achieve the standards requested by the NC DEHNR. These requirements are more fully described in our letter to the Naval Facilities Engineering Command dated 15 September 1992.

Ms. Berry
21 September 1992
page 2

2. The proposed additional treated groundwater flows will be associated with the interim Remedial Action for the Shallow Aquifer at Hadnot Point Industrial Area solely.
3. The NC DEHNR, Division of Environmental Management reserves the right to re-enter the existing N.P.D.E.S. and S.O.C. permit if the proposed groundwater treatment system does not perform within the standards established or if the Hadnot Point Sewage Treatment Plant is adversely effected.

If you have any questions please contact me at (919) 733-2801.

Sincerely,



E. Peter Burger, P.E.
Environmental Engineer
NC Superfund Section

EPB/kc

cc: Coleen Sullins, NC DEHNR DEM
Michelle Glenn, US EPA Region IV
George Radford, MCB Camp Lejeune